

# TYPE APPROVAL CERTIFICATE

**This is to certify:****That the Burner Management System**with type designation(s)  
**LFL 1.335**

Issued to

**Siemens AG**  
**Rastatt, Germany**is found to comply with  
**DNV GL rules for classification – Ships, offshore units, and high speed and light craft****Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**

<b>Temperature</b>	<b>B</b>
<b>Humidity</b>	<b>B</b>
<b>Vibration</b>	<b>A</b>
<b>EMC</b>	<b>A</b>
<b>Enclosure</b>	<b>Required protection according to the Rules to be provided upon installation on board.</b>

Issued at **Hamburg** on **2018-10-24**for **DNV GL**This Certificate is valid until **2023-10-23**.DNV GL local station: **Augsburg**Approval Engineer: **Andreas Andrecht**.....  
**Arne Schaarmann**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-029256-1**  
Certificate No: **TAA0000229**  
Revision No: **1**

## Product description

Burner control systems for burners of medium to high capacity

LFL1.335 Automatic burner control system for gas, oil or dual-fuel burners of medium to high capacity in intermittend operation, UV-detector QRA  
Rated voltage: 230 V AC ( 110 V AC )  
Rated frequency: 50 - 60 Hz,

## Type Approval documentation

Test report : DVGW Forschungsstelle 95/464/79/745  
DVGW Forschungsstelle 95/62990/749  
DVGW CE-0085AP0001  
SBT catalogues: CC1N7785D, CC1N7153D, CC1N7451D

## Tests carried out

Guidlines for the Performance of Type Approvals Edition 2003,  
DIN EN298 (1994), DIN EN 230 (1991)

## Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE