



Presentation example PME75

Presentation example LME75

## PME75.831Ax

## Program module for burner control LME75.000Ax

### User Documentation

- Application:**
- 1-stage or modulating, direct or pilot-ignited forced draft burners
  - With independent ignition load position below or above the low-fire position
  - Integrated actuator control via 3-position controller or analog signal
  - Integrated valve proving function, can be switched via separate digital input for simple handling on dual-fuel burners
  - Prepurge position at high-fire to low-fire
  - Flame failure response time can be parameterized.  
For example, for burners to EN 676 or industrial thermo processing plants to EN 746 Part 2
  - Continuous operation >24 hours of uninterrupted operation

The PME75.831Ax and this user documentation are intended for original equipment manufacturers (OEMs) using the LME75.000Ax with PME75.831Ax in or on their products.



#### Note!

This documentation is only valid together with Basic Documentation LME75/LME76 (P7156)!

# Contents

<b>1</b>	<b>Supplementary documentation .....</b>	<b>4</b>
<b>2</b>	<b>Warning notes .....</b>	<b>5</b>
<b>3</b>	<b>Typographical conventions .....</b>	<b>6</b>
3.1	Safety notes .....	6
3.2	Qualified personnel.....	6
3.3	Correct use .....	6
<b>4</b>	<b>PME75.831Ax program sequence .....</b>	<b>7</b>
<b>5</b>	<b>List of the phase display .....</b>	<b>13</b>
<b>6</b>	<b>Fuel trains (examples) .....</b>	<b>15</b>
6.1	Gas direct ignition (G), 1-stage or modulating, without valve proving.....	15
6.2	Gas pilot ignition 2 (Gp2), 1-stage or modulating, without valve proving.....	16
6.3	Gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving, alternately lighting pilot burner .....	17
6.4	Gas direct ignition 1 (G), 1-stage or modulating, with valve proving.....	18
<b>7</b>	<b>Description of inputs on LME75 .....</b>	<b>20</b>
7.1	Air pressure switch terminal X3-02 .....	20
7.1.1	Air pressure switch → specified time .....	20
7.1.2	Air pressure switch input.....	21
7.1.3	Response time to loss of air pressure.....	22
7.1.4	Omission of prepurging after standard shutdown according to EN 676:2003 + A2:2008 Chapter 4.4.1.2 Prepurging .....	22
7.1.5	Extension of the prepurging process .....	23
7.1.6	Extension of the postpurging process.....	23
7.2	Gas pressure switch-min terminal X5-01 .....	24
7.2.1	Response to loss of gas pressure switch-min input signal gas pressure.....	24
7.2.2	Evaluation of gas pressure switch-min input signal .....	25
7.3	Function input gas pressure switch-max or valve proving terminal X2-02.....	26
7.3.1	Function input for deactivating valve proving.....	26
7.3.2	Function input gas pressure switch-max.....	27
7.4	Valve proving of the fuel valves .....	28
7.4.2	Pressure switch valve proving terminal X9-04 .....	29
7.4.3	Valve proving with separate pressure switch.....	30
7.4.4	Program sequence with valve proving .....	31
7.4.5	Valve proving – calculation of leakage rate .....	32
7.5	Flame detector input .....	33
7.5.1	Ionization probe terminal X10-06 .....	33
7.5.2	QRA7 / QRI terminal X10-05 .....	34
7.6	Limitation of restarts.....	36
7.6.1	Restart in the event of loss of flame.....	36
7.6.2	Restart in the event of <i>no establishment of flame at the end of safety time</i> ..	36
7.7	Logical combination and evaluation.....	37
7.8	Parameterization of the extraneous light tolerance time in standby .....	37

7.9	Analog input load controller terminal X65.....	38
7.10	External load controller (ON/OFF) terminal X5-03 .....	41
7.11	Safety loop terminal X3-04 .....	43
<b>8</b>	<b>Description of outputs on LME75 .....</b>	<b>44</b>
8.1	Fan motor terminal X2-01 .....	44
8.2	Alarm / remote lockout reset terminal X2-03 .....	44
8.2.1	Alarm terminal X2-03 pin 3 .....	44
8.2.2	Remote lockout reset (reset) terminal X2-03 pin 1 .....	44
8.3	Actuator terminal X2-09.....	45
8.3.1	Connection of feedback actuator position with ASZ in actuator at terminal X66 .....	46
8.3.2	Engineering notes.....	46
8.3.3	Pin assignment of actuators for terminal X2-09 at LME75 .....	47
8.3.3.1.	SQN70 / SQN71 .....	47
8.3.3.2.	SQN72.....	47
8.3.3.3.	SQM5 .....	48
8.3.3.4.	SQM40 / SQM41 .....	48
8.4	Ignition transformer terminal X4-02 .....	61
8.5	Safety valve terminal X6-03.....	61
8.6	Pilot valve PV terminal X7-01 / X7-04 .....	62
8.7	Fuel valve V1 terminal X7-02 / X7-04.....	63
8.8	Fuel valve V2 terminal X7-01 / X7-02.....	64
<b>9</b>	<b>Time table and settings.....</b>	<b>65</b>
<b>10</b>	<b>Inputs and outputs/internal connection diagram .....</b>	<b>69</b>
<b>11</b>	<b>Parameter list (AZL2/ACS410).....</b>	<b>70</b>
<b>12</b>	<b>Error code list .....</b>	<b>78</b>
<b>13</b>	<b>Key .....</b>	<b>80</b>
<b>14</b>	<b>List of figures .....</b>	<b>81</b>

# 1 Supplementary documentation

Product type	Designation	Type of documentation	Documentation number
LME	Burner control	Environmental declaration	E7105 *)
LME	Burner control	Product range overview	Q7101
LME75 / LME76	Burner control	Data Sheet	N7156
LME75 / LME76	Burner control	Basic documentation	P7156
PME	Program module	Environmental declaration	E7105.1 *)

\*) On request only



## Note!

This document only refers to the product type – not the *product designation*. See the table below for details.

Product type	Product designation
AZL2	Display and Operating Unit
LFS1	Flame safeguard
QRA7	UV flame detector
QRI	Infrared flame detector
SQN70	Actuator
SQN71	Actuator
SQN72	Actuator
SQN74	Actuator
SQN75	Actuator
SQM40	Actuator
SQM41	Actuator
SQM5	Actuator
QPL	Pressure switch
AGG3	Connector set
AGG9	Connector set
OCI410	BC interface
ACS410	PC software
ASZ	Potentiometers

## 2 Warning notes



### Warning!

All the safety, warning, and technical notes given in the Basic Documentation LME75/LME76 (P7156) also apply to this document in full.

To avoid personal injury or damage to property or the environment, the following warning notes must be observed.

The LME75.000Ax is a safety device. Do not open, interfere with or modify the unit. Siemens does not assume responsibility for damage resulting from unauthorized interference!



### Warning!

On the OEM access level of the LME75, it is possible to make parameter settings that differ from application standards. When setting the parameters, it is important to ensure that the application will run safely in accordance with legal requirements. Failure to observe this information poses a risk of damaging the safety functions.



### Warning!

**Risk of damage to the switching contacts!**

If the external primary fuse (Si) is blown due to overload or short-circuit at the terminals, the LME75 must be replaced.

# 3 Typographical conventions

## 3.1 Safety notes

This User Documentation contains notes which must be observed to ensure your personal safety and to prevent material damage. The instructions and notes are highlighted by warning triangles or a hand symbol and are presented as follows, depending on the hazard level:



**Warning** means that death, severe personal injury or substantial damage to property **can** occur if adequate precautionary measures are not taken.



**Caution** means that minor personal injury or property damage **can** occur if adequate precautionary measures are not taken.



**Note** draws your attention to **important information** on the product, on product handling, or to a special part of the documentation.

## 3.2 Qualified personnel

Only **qualified personnel** are allowed to start up and operate the equipment. Qualified personnel in the context of the safety-related notes contained in this User Documentation are persons who are authorized to commission, ground, and tag units, systems, and electrical circuits in compliance with established safety practices and standards.

## 3.3 Correct use

*Note the following:*

The equipment may only be used for the applications described in the technical documentation and only in conjunction with devices or components from other suppliers that have been approved or recommended by Siemens.  
The product can only function correctly and safely if shipped, stored, set up, and installed correctly, and operated and maintained with care.

# 4 PME75.831Ax program sequence

→ For fuel trains G without/with valve proving, Gp1 with valve proving, and Gp2 without valve proving




Figure 1: Program sequence for fuel trains G without/with valve proving, Gp1 with valve proving, and Gp2 without valve proving




## Variant 1:

With actuator control (parameter 515.01 = 1)

Ignition load < low-fire (parameter 259.01 > 0 seconds)

Prepurging at high-fire (parameter 515.00 = 1)



7156d65en/0422

Figure 2: Program sequence for fuel trains G without/with valve proving, Gp1 with valve proving, and Gp2 without valve proving



**Variant 2:**  
 With actuator control (parameter 515.01 = 1)  
 Ignition load > low-fire (parameter 259.01= 0 seconds)  
 Prepurging at high-fire (parameter 515.00 = 1)






Figure 3: Program sequence for fuel trains G without/with valve proving, Gp1 with valve proving, and Gp2 without valve proving

Variant 3:  
 With actuator control (parameter 515.01 = 1)  
 Ignition load < low-fire  
 (parameter 259.01 > 0 seconds and parameter 259.02 = 0 seconds)  
 Prepurging at low-fire (parameter 515.00 = 0)




Figure 4: Program sequence for fuel trains G without/with valve proving, Gp1 with valve proving, and Gp2 without valve proving



**Variant 4:**  
 With actuator control (parameter 515.01 = 1)  
 Ignition load > low-fire  
 (parameter 259.01 = 0 seconds and parameter 259.02 > 0 seconds)  
 Prepurging at low-fire (parameter 515.00 = 0)







Figure 5: Program sequence for fuel trains G without/with valve proving, Gp1 with valve proving, and Gp2 without valve proving

 Variant 5:  
 Operation without actuator control (parameter 515.01 = 0)!  
 A Dbr3 wire link is required at terminal X2-09B from pin 7 to pin 8 required.

 **Warning!**  
**Voltage at actuator plug-in space X2-09!**  
 A suitable cover provided by the OEM must provide protection against electric shock hazard at plug-in space X2-09. In terms of design, stability, and protection, covers must conform to EN 60730. Failure to observe this poses a risk of electric shock.

*)	During the actuator running phases, the actuator feedback signal must first be OFF, then ON
**)	<p>Setting of ignition load cam switch/low-fire cam switch, example of 65 s/90° (SQM4x.3)</p> <p>Parameter 259.01 = max. 37.5 s</p> 
*1	Valve proving during prepurging (t1), if parameter 241.00 = 1 and - parameter 241.02 = 1 or - parameter 241.01 = 0 or - parameter 234 (postpurge time) = 0 seconds
*2	Valve proving during postpurging (t8), if parameter 241.00 = 1 and - parameter 241.02 = 1 or - parameter 241.01 = 1 and - parameter 234 (postpurge time) >0 seconds
*3	Valve proving is not performed
*4	Valve proving only in fuel trains <b>G</b> and <b>Gp1</b>
*5	No prepurging (t1), if parameter 222 = 0 and there has been a successful shutdown
*6	Detector test interval 5 s/5 min in depending on parameter 180
*7	Only at fuel train G: For direct ignition, a wire link Dbr2 between pilot valve PV terminal X7-01 pin 3 and fuel valve V2 terminal X7-02 pin 3 is required

## 5 List of the phase display

Phase number display		LED	Function
7-segment	AZL2		
LOC	LOC	Red	Lockout phase
<b>Standby</b>			
OFF	OFF	OFF	Standby, waiting for heat request
P08	Ph08	OFF	Power ON / test phase (e.g., detector test)
<b>Startup</b>			
P21	Ph21	Yellow	Safety valve ON, air pressure switch in no-load position Actuator travels to CLOSED position
P22	Ph22	Yellow	Part 1: Fan motor ON Part 2: Specified time air pressure switch Message (timeout), stabilization air pressure switch
P24	Ph24	Yellow	Actuator travels to the prepurge position (timeout)
P30	Ph30	Yellow	Part 1: Prepurge time without extraneous light test Valve proving during prepurging (t1), if Parameter 241.00 = 1 and Parameter 241.02 = 1 or Parameter 241.01 = 0 or Parameter 234 (postpurge time) = 0 seconds Part 2: Prepurging with extraneous light test (1 second)
P36	Ph36	Yellow	Actuator closed in ignition load / low-fire and Parameter 259.02: Actuator opens at a position > ignition load
P38	Ph38	Flashing yellow	Preignition time
P40	Ph40	Flashing yellow	First safety time / ignition transformer ON
P42	Ph42	Green	Safety time (ignition transformer OFF), flame check
P44	Ph44	Green	Interval: End of safety time and fuel valve V2 ON
P50	Ph50	Green	Second safety time, fuel valve V2 ON
P52	Ph52	Green	Interval until release of load controller target (analog or 3-position step input)
P54	Ph54	Green	Parameter 259.01: Actuator opens at a position > low-fire Parameter 260: Actuator closes at low-fire
<b>Operation</b>			
xx	oP:xx	Green	Operation (modulation), actual load displayed in percent
<b>Shutdown</b>			
P10	Ph10	OFF	Actuator travels to CLOSED position (home run)
P70	Ph70	Yellow	Stop operation
P72	Ph72	Yellow	Stop operation
P74	Ph74	Yellow	Postpurge time Valve proving during postpurging (t8), if Parameter 241.00 = 1 and Parameter 241.02 = 1 or Parameter 241.01 = 1 and Parameter 234 (postpurge time) >0 seconds

Phase number display		LED	Function
7-segment	AZL2		
<b>Valve proving</b>			
P80	Ph80	Yellow	Test space evacuating
P81	Ph81	Yellow	Test time atmospheric pressure
P82	Ph82	Yellow	Test space filling
P83	Ph83	Yellow	Test time gas pressure
<b>Safety shutdown phases</b>			
P01	Ph01	Yellow / red	Undervoltage / overvoltage
P02	Ph02	Yellow	Safety shutdown, followed by a non-alterable lockout with interlocking → e.g., safety loop open
P04	Ph04	Green / red	Extraneous light during burner startup Timeout, extraneous light tolerance time in standby Parameter 216 → Non-alterable lockout
P90	Ph90	Yellow	Gas pressure switch-min open Parameter 223 = 0 → Safety shutdown and start prevention Parameter 223 = 1 → Non-alterable lockout

# 6 Fuel trains (examples)



**Note!**  
Modulating or multistage fuel trains for gas are only permitted in a pneumatic ratio control system!

## 6.1 Gas direct ignition (G), 1-stage or modulating, without valve proving




Figure 6: Fuel train gas direct ignition (G), 1-stage or modulating, without valve proving

\*) Alternatively, parameter 241.00 can be set to 0

\*\*\*) Optional

## 6.2 Gas pilot ignition 2 (Gp2), 1-stage or modulating, without valve proving




Figure 7: Fuel train gas pilot ignition 2 (Gp2), 1-stage or modulating, without valve proving

\*) Alternatively, parameter 241.00 can be set to 0

\*\*) Optional



## 6.3 Gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving, alternately lighting pilot burner




Figure 8: Fuel train gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving, alternately lighting pilot burner

\*) Optional



### Note!

In the case of applications with gas pilot ignition and fuel train **Gp1**, the switching contact on the connected actuator switches pilot valve PV on terminal X7-01.


Please observe the maximum permissible contact rating of the connected switching cam for the actuator in use.

If the switching capacity of the cam switch in the actuator is lower than the current draw of the pilot valve, an external relay may be connected.

Please also observe the maximum permissible contact rating for terminal X7-01:

Rated voltage	120 V AC	230 V AC
	50/60 Hz	50/60 Hz
Rated current	1 A	1 A
Power factor	$\cos\varphi > 0.4$	$\cos\varphi > 0.4$

## 6.4 Gas direct ignition 1 (G), 1-stage or modulating, with valve proving



### Fuel valve control




Figure 9: Fuel train gas direct ignition 1 (G), 1-stage or modulating, with valve proving

\*) Optional

#### Legend

- Without Dbr2
- - - With Dbr2



#### Note!

When activating valve proving (e.g., on shutdown), the load on the fuel valve terminals is restricted.

Fuel valve V1 terminal X7-04 pin 4 / fuel valve V2 terminal X7-02 pin 3

Nominal voltage	120 V AC	230 V AC
	50/60 Hz	50/60 Hz
Nominal current	1 A	1 A
Power factor	$\cos\varphi > 0.4$	$\cos\varphi > 0.4$

If, on the other hand, the terminal load is applied with maximum 2 A rated current ( $\cos\varphi > 0.4$ ), the design lifetime is about 100,000 burner start cycles.



**Note!**

In the case of gas direct ignition (G), fuel valve V2 is switched on via terminal X7-01 or via the switching contact on the connected actuator.

Please observe the maximum permissible contact rating of the connected switching cam for the actuator in use.

If the switching capacity of the cam switch in the actuator is lower than the current draw of the fuel valve V2, an external relay may be connected.

Please also observe the maximum permissible contact rating for terminal X7-01:

Rated voltage	120 V AC	230 V AC
	50/60 Hz	50/60 Hz
Rated current	1 A	1 A
Power factor	$\cos\varphi > 0.4$	$\cos\varphi > 0.4$

## 7 Description of inputs on LME75



### Note!

This chapter covers the basic features of the LME75 inputs.  
For an exact evaluation and activation of the inputs, see the program sequences in chapter 4 *PME75.831Ax program sequence*.

### 7.1 Air pressure switch terminal X3-02




Figure 10: Air pressure switch terminal X3-02

#### 7.1.1 Air pressure switch → specified time

Parameter	Function
224	Air pressure switch → specified time

Input for connection of an air pressure switch.

Within the specified time ( $t_{10}$ ) (parameter 224), the air pressure switch must close after switching on the fan and – if necessary – after reaching the high-fire position of the actuator (parameter 515.01 = 1).

Otherwise, a non-alterable lockout takes place (lockout code Loc: 3).

The air pressure switch must have an NO contact.

The air pressure switch test (specified time) takes place within phase 22.

## 7.1.2 Air pressure switch input

Parameter	Function
235.00	Air pressure switch input 0 = no evaluation of the air pressure switch during operation (evaluation only during prepurging and, if necessary, postpurging) 1 = evaluation of the air pressure switch during prepurging and postpurging, as well as when in the operating position

Parameter access: OEM level

Evaluation of the air pressure switch input signal can be changed via the selection in parameter 235.00.

Where parameter 235.00 = 0

No evaluation of the air pressure switch during burner operation (from phase 44 to the end of phase *oP:xx*). Evaluation only during prepurging and, if necessary, postpurging (according to EN 676:2003 + A2:2008, Chapter 4.3.4.11 *Air monitoring device*).

Parameter 235.00 = 1

Evaluation of the air pressure switch from phase 22 (fan motor ON).

If no air pressure switch is required, e.g., for atmospheric applications, a wire link to the fan output must be fitted (terminal X3-02 pin 1 to terminal X2-01 pin 3).



### Warning!

**The OEM must check to see whether the burner can be operated without an air pressure switch. This may necessitate a special approval, depending on the application.**

### 7.1.3 Response time to loss of air pressure

Parameter	Function
235.01	Air pressure switch – response time to loss 0 = typically 0.7 seconds ≥ 0 = additional delay in reaction to faulty air pressure switch

Parameter access: OEM level

Parameter 235.01 ≥ 0

Additional delay on loss of air pressure is typical 0.7 seconds + set delay.

Parameter 235.01 = 0.294 (factory setting)

The response time to a faulty air pressure switch is ≤1 second.

Example

Typically, 0.7 s + 2.058 s = 2.758 s (corresponds to < 3 s according to EN 746-2, Chapter 5.2.5.3.4.2 *Maximum safety times for burners without fan*, Table 2)

### 7.1.4 Omission of prepurging after standard shutdown

according to EN 676:2003 + A2:2008 Chapter 4.4.1.2

#### Prepurging

Parameter	Function
222	Prepurging 0 = inactive 1 = active

Parameter access: OEM level

Parameter 222 = 0

Omission of prepurging after standard shutdown

(according to EN 676, Chapter 4.4.1.2 *Prepurging (Prepurge)*)

Restrictions:

Prepurging must be performed:

- Following unlocking from a non-alterable lockout
- After 24 hours of standby
- After power OFF/ON
- Start prevention, safety shutdown due to gas shortage
- During valve proving of the fuel valves during prepurging  
(Parameter 241.00 = 1 and Parameter 241.01 = 0)

Parameter 222 = 1

Prepurging on every burner startup.

## 7.1.5 Extension of the prepurging process

Parameter	Function
225.00	Prepurge time (t1)
225.01	Multiplicator of the prepurge time (t1) (extension of prepurge time)

If required, the prepurge time can be extended to >20 minutes and up to 87 hours. The two parameters 225.00 (prepurge time) and parameter 225.01 (multiplicator for prepurge time) can be used to this end.

The prepurge time corresponds to the time set in parameter 225.00 multiplied by parameter 225.01.

Example for a prepurge time of 1 hour:

Parameter 225.00 = 1203.048 s x parameter 225.01 = 3

→ 3609.144 s ~ 60.15 min ~ 1 h

Setting the prepurging to 1 hour can also be achieved with other combinations of the two parameters.

The factory setting is:

Parameter 225.00 = 29.106 s x parameter 225.01 = 1 → 29.106 s

## 7.1.6 Extension of the postpurging process

Parameter	Function
234.00	Postpurge time (t8) (no extraneous light test)
234.01	Multiplicator of postpurge time (t8) (extension of postpurging)

If required, the postpurge time can be extended to >20 minutes and up to 87 hours. The two parameters 234.00 (postpurge time) and parameter 234.01 (multiplicator for postpurge time) can be used to this end.

The postpurge time corresponds to the time set in parameter 234.00 multiplied by parameter 234.01.

Example for a postpurge time of 1 hour:

Parameter 234.00 = 1203.048 s x parameter 234.01 = 3

→ 3609.144 s ~ 60.15 min ~ 1 h

Setting the postpurge to 1 hour can also be achieved with other combinations of the two parameters.

The factory setting is:

Parameter 234.00 = 0 s x parameter 234.01 = 1 → 0 seconds (no postpurge)

## 7.2 Gas pressure switch-min terminal X5-01




Figure 11: Gas pressure switch-min terminal X5-01

Parameter	Function
223	Gas pressure switch-min – response to loss 0 = safety shutdown and start prevention 1 = non-alterable lockout
236	Input pressure switch-min 0 = permanent evaluation 1 = in operation only (after second safety time)

Parameter access: OEM level

### 7.2.1 Response to loss of gas pressure switch-min input signal gas pressure

Parameter access: OEM level

The response to loss of *gas pressure switch-min input signal* gas pressure can be changed via the selection in parameter 223.

Parameter 223 = 0

If the gas pressure switch-min fails, a safety shutdown and start prevention are performed.

Evaluation of the air pressure switch from phase 30 (prepurging).

During start prevention, the yellow signal lamp lights up and the safety loop is active.

The LME75 is in phase 90.

Once the gas pressure has been restored, a restart is carried out.

Parameter 223 = 1

If the *gas pressure switch-min* gas pressure fails, a non-alterable lockout is performed (Loc: 20).



## 7.2.2 Evaluation of gas pressure switch-min input signal

Parameter access: OEM level

Evaluation of the *gas pressure switch-min input signal* gas pressure can be changed via the selection in parameter 236.

Parameter 236 = 0

Evaluation of the gas pressure switch from phase 30 (prepurging).

Permanent evaluation (except for in the first and second safety times).

Parameter 236 = 1

In operation only (after second safety time, e.g., according to Canadian standard CSA B149.3-10, Chapter 9.5.3 *Pilot Gas Supply*, or EN 676:2003 + A2:2008, Annex B).

## 7.3 Function input gas pressure switch-max or valve proving terminal X2-02




Figure 12: Gas pressure switch-max or valve proving terminal X2-02

Parameter	Function
237.00	Input for POC / CPI (not adjustable) 0 = inactive
237.01	Function input valve proving or gas pressure switch-max terminal X2-02 0 = deactivation of valve proving (via external switching contact) 1 = input for gas pressure switch-max

Various functions can be activated or deactivated via function input terminal X2-02 pin 3 / pin 4, depending on the settings for parameter 237.01.



### Note!

Only one function can be selected at function input terminal X2-02 during running time.

Parameter access:  
Parameter 237.01 → OEM level

### 7.3.1 Function input for deactivating valve proving

An external switch can be connected at function input terminal X2-02 pin 3 / pin 4, which can be used to switch valve proving on/off within the program sequence. A closed switch (or a wire link) deactivates valve proving. An open switch activates valve proving.

Parameter settings:  
Parameter 237.01 = 0 (deactivation of *valve proving*)



### Warning!

Where parameter 237.01 = 0, only one external switch may be connected to deactivate the valve proving.

It is not permitted to have a POC/CPI or gas pressure switch-max.

If this is not observed, the safety function of the valve proving or of the gas pressure switch-max may be impaired.

### 7.3.2 Function input gas pressure switch-max

A gas pressure switch-max can be connected at function input terminal X2-02 pin 3 / pin 4.

Setting the parameter:

Parameter 237.01 = 1(input for gas pressure switch-max)

The gas pressure switch-max function can be activated by parameter 237.01 = 1. When the gas pressure switch-max function is active, the gas pressure switch-max monitors the maximum gas pressure and opens if it is exceeded. Monitoring takes place during operation, from the second interval (t5) on.

If the maximum gas pressure is exceeded and the gas pressure switch-max opens, a non-alterable lockout is performed with lockout code 21. Before the second interval, there is no reaction if the gas pressure switch-max opens.

## 7.4 Valve proving of the fuel valves

Valve proving is dependent on parameter 241.00 and/or the valve proving input ON/OFF or the settings of parameter 237.01 for function input terminal X2-02 (see Chapter *Valve proving function input ON/OFF*). It is employed to detect leaking fuel valves and, if necessary, to prevent the fuel valves from opening or ignition from being switched on. A non-alterable lockout will be initiated in these cases.

### 7.4.1 Function input for valve proving ON/OFF

An external switch can be connected at function input terminal X2-02 pin 3 / pin 4. This can be used to switch valve proving on/off within the program sequence.

Parameter settings

Parameter 237.00 = 0 (not adjustable)

Parameter 237.01 = 0 (*valve proving ON/OFF* function)



#### **Warning!**

**Where parameter 237.01 = 0, only one external switch may be connected to deactivate the valve proving.**

**It is not permitted to have a POC/CPI or gas pressure switch-max.**

**If this is not observed, the safety function of the valve proving function may be impaired.**

The *valve proving ON/OFF* function executed via an external switch can be activated by parameter 237.01 = 0. When the *valve proving ON/OFF* function is active, an external switch can be used to switch valve proving on/off within the program sequence. A closed switch (or a wire link) deactivates valve proving. An open switch activates valve proving.

## 7.4.2 Pressure switch valve proving terminal X9-04




Figure 13: Pressure switch valve proving terminal X9-04

Parameter	Function
237.00	Input for POC / CPI (not adjustable) 0 = inactive
237.01	Function input terminal X9-04 0 = deactivation of valve proving (via external switching contact) 1 = input for gas pressure switch-max
241.00	Valve proving 0 = OFF 1 = ON
241.01	Valve proving 0 = during prepurge time 1 = during postpurge time
241.02	Valve proving 0 = according to parameter 241.01 1 = during prepurge time and postpurge time
242	Valve proving – test space evacuating (td4)
243	Valve proving – test time atmospheric pressure (td1)
244	Valve proving – test space filling (td3)
245	Valve proving – test time gas pressure (td2)

### 7.4.3 Valve proving with separate pressure switch




Figure 14: Valve proving with separate pressure switch

Step 1: td4 –test space evacuating.  
Fuel valve on the burner side is opened to bring the test space to atmospheric pressure.

Step 2: td1 – test time atmospheric pressure  
When the fuel valve has closed, the gas pressure in the test space must not exceed a certain level.

Step 3: td3 – test space filling.  
Fuel valve on the mains side opens to fill the test space.

Step 4: td2 – test time gas pressure  
When the fuel valve has closed, the gas pressure in the test space must not drop below a certain level.

Key	
td1	Test time atmospheric pressure
td2	Test time gas pressure
td3	Test space filling
td4	Test space evacuating
V...	Fuel valve
P LT	Pressure switch valve proving
	Input/output signal 1 (ON)
	Input/output signal 0 (OFF)
	Permissible signal 1 (ON) or 0 (OFF)

Query logic of gas pressure switch for valve proving:  
Gas pressure present → pressure switch open  
Gas pressure not present → pressure switch closed

Recommendation:  
Perform valve proving on shutdown (see also chapter 7.4.4 “Program sequence with valve proving”).

No.	Parameter
241.00	Valve proving 0 = OFF 1 = ON <sup>1)</sup>
242	Valve proving – test space evacuating (td4)
243	Valve proving – test time atmospheric pressure (td1)
244	Valve proving – test space filling (td3)
245	Valve proving – test time gas pressure (td2)

<sup>1)</sup> Valve proving during postpurging (t8), if parameter 234 > 0 (postpurge time) and parameter 241.01 = 1

## 7.4.4 Program sequence with valve proving

Valve proving can be parameterized to take place on startup, shutdown, or both.

Valve proving takes places during prepurging and/or postpurging depending on the parameter settings.

The following dependencies or deviations may apply:

### During startup

Valve proving during startup is performed when parameter 241.01 = 0 or parameter 241.02 = 1.

Valve proving during startup is performed after a reset from a non-alterable lockout, after mains voltage ON, and when the postpurge time = 0 seconds (parameter 234 = 0 seconds).

In that case, valve proving takes place at the same time as prepurging. This means that the prepurge time corresponds to at least the sum of all 4 valve proving parameters (242, 243, 244, and 245).

### During shutdown

Valve proving during shutdown is performed if parameter 241.01 = 1 and the postpurge time > 0 seconds (parameter 234 > 0 seconds). If no postpurge time is parameterized, valve proving takes place during startup when prepurging. During shutdown (heat request OFF), it is checked if parameter 241.00 = 1 (valve proving ON) and parameter 234 ≠ 0 seconds before the fuel valves close.

This means that first, fuel valve V1 is closed. Fuel valve V2 remains open. This is so that the remaining gas in the test space can be burned. The postpurge time runs at the same time as valve proving. This means that the postpurge time corresponds to at least the sum of all 4 valve proving parameters (242, 243, 244, and 245).

The actuator remains in the last operating position during postpurging and valve proving.



### Warning!

**The OEM must set the evacuation, filling, and test times for atmospheric or mains pressure on every plant in compliance with the requirements of EN 1643. Failure to observe these poses a risk of damaging the safety functions.**

Both test times must be set correctly. A check must be performed to verify that the gas required for the test may be fed into the combustion chamber (on the relevant application). The test times are safety-related. After an interruption to the mains supply, unlocking, or in the case of aborted or prevented valve proving, the LME75 will perform valve proving the next time it is started up (only when valve proving is activated). In the case of valve proving, prepurging is active during the startup phase, even if it has been deactivated.

Examples of aborted valve proving:

When the safety loop input or the start release gas input (containing pressure switch-min) opens during valve proving.

## 7.4.5 Valve proving – calculation of leakage rate

$$t_{\text{Test}} = \frac{(P_G - P_W) \cdot V \cdot 3600}{P_{\text{atm}} \cdot Q_{\text{Leak}}}$$

$Q_{\text{Leak}}$	in l/h	Leakage rate in liters per hour
$P_G$	in mbar	<b>Overpressure</b> between the fuel valves at the beginning of the test phase
$P_W$	in mbar	Overpressure set on the pressure switch (normally 50% of the gas inlet pressure)
$P_{\text{atm}}$	in mbar	<b>Absolute air pressure</b> (1,013 mbar normal pressure)
$V$	in l	Volume between the fuel valves (test volume) including valve volume and pilot path if present
$t_{\text{Test}}$	in s	Test time



## 7.5 Flame detector input

### 7.5.1 Ionization probe terminal X10-06




Figure 15: Ionization probe terminal X10-06

Parameter	Function
179	Logical combination of both flame signal amplifier channels 0 = flame signal amplifier channels are logically combined with an <b>OR</b> operation (ionization <b>OR</b> QRA7 / QRI) 1 = flame signal amplifier channels are logically combined with an <b>AND</b> operation (ionization <b>AND</b> QRA7 / QRI)
217.00	Flame signal flame-on response time (extension) (not adjustable) 0 = maximum 1 second with ionization probe, QRA7 or QRI
217.01	Flame signal flame-out response time (extension) 0 = maximum 1 second with ionization probe, QRA7 or QRI ≥ 0 = additional extension to reaction to a flame fault
240	Restart in the event of loss of flame during operation and in the event of no flame at the end of the safety time 0 = no restart 1 = no restart 2 = 1x restart 3 = 2x restart 4 = 3x restart
954.00	Intensity of flame for ionization probe (0...100%)

#### Response time

Parameter access: OEM level

Parameter 217.01 = 0

The response time to a flame fault (flame fault response time) is ≤1 second.

Parameter 217.01 ≥ 0

Additional delay on flame fault (flame fault response time) is 1 second + set delay.

Example

1 s + 1.911 s = 2.911 s ~3 s (e.g., EN 746-2, Chapter 5.2.5.3.4.2 *Maximum safety times for burners without fan*, Table 2)



#### Caution!

Ensure the ionization probe connection wires are connected properly and in-phase.

If connected incorrectly to terminal X10-05, there is a risk that the LME75 and ionization probe may malfunction.

## 7.5.2 QRA7 / QRI terminal X10-05




Figure 16: QRA7 / QRI terminal X10-05

Parameter	Function
179	Logical combination of both flame signal amplifier channels 0 = flame signal amplifier channels are logically combined with an <b>OR</b> operation (ionization <b>OR</b> QRA7/QRI) 1 = flame signal amplifier channels are logically combined with an <b>AND</b> operation (ionization <b>AND</b> QRA7/QRI)
180	Test interval for flame detector QRA7/QRI 0 = ≤ 5 minutes 1 = ≤ 5 seconds
217.00	Flame signal flame-on response time (extension) (not adjustable) 0 = maximum 1 second with ionization probe, QRA7 or QRI
217.01	Flame signal flame-out response time (extension) 0 = maximum 1 second with ionization probe, QRA7 or QRI ≥ 0 = additional extension to reaction to a flame fault
240	Restart in the event of loss of flame during operation and in the event of no flame at the end of the safety time 0 = no restart 1 = no restart 2 = 1x restart 3 = 2x restart 4 = 3x restart
954.01	Intensity of flame QRA7 / QRI (0...100%)

### Response time

Parameter access: OEM level

Parameter 217.01 = 0

The response time to a flame fault (flame signal flame-out response time) is ≤1 second.

Parameter 217.01 ≥ 0

Additional delay on flame fault (flame signal flame-out response time, extension) is 1 second + set delay.

Example

1 s + 1.911 s = 2.911 s ~3 s (e.g., EN 746-2, Chapter 5.2.5.3.4.2 *Maximum safety times for burners without fan*, Table 2)



### Caution!

Ensure the QRA7/QRI connection wires are connected properly and in-phase. If connected incorrectly to terminal X10-05, there is a risk that the LME75 and QRA7/QRI may malfunction.

Test interval for continuous operation

Parameter access: OEM level

The interval for testing the QRA7/QRI for continuous operation can be changed via the selection in parameter 180.

Parameter 180 = 0

The flame detector test in the operating position is triggered every 5 minutes.

Parameter 180 = 1

The flame detector test in the operating position is triggered every 5 seconds.

Parameter	Function
180	Test interval for flame detector QRA7/QRI 0 = ≤ 5 minutes 1 = ≤ 5 seconds



Note

Flame detector test failed!

A failed flame detector test (QRA7 / QRI) can lead to a non-volatile lockout (lockout code Loc: 10) or an extraneous light error (lockout code Loc: 4).



**Warning!**

**Risk of mixing up with LME71/LME73!**

**Only QRA7 or QRI may be connected to connection terminal X10-05.**

**Only an ionization probe may be connected to connection terminal X10-06.**

**Failure to observe this information poses a risk of loss of safety functions or a fault in the LME75 equipment.**



**Warning!**

**The QRA7 input is not short-circuit-proof!**

**A short-circuit at terminal X10-05 pin 2 to ground can destroy the QRA7 input.**

**Failure to observe this information poses a risk of loss of device functions.**



**Warning!**

**It is not permitted to connect the LFS1. Failure to observe this information poses a risk of damaging the LME75.**



Note!

If an ionization probe is operated a QRA7 or QRI simultaneously, be sure to note the parameter settings!

## 7.6 Limitation of restarts

Parameter	Functions
240	Restart in the event of loss of flame during operation and in the event of no flame at the end of the safety time 0 = no restart 1 = no restart 2 = 1x restart 3 = 2x restart 4 = 3x restart

### 7.6.1 Restart in the event of loss of flame

If the flame is lost during operation, several restarts per controlled startup can be performed via the control thermostat or pressurestat, or else a non-alterable lockout will be initiated.

With restarts from the operating position (loss of flame), the flame must have been established on completion of the safety time, or else a non-alterable lockout will be initiated.

### 7.6.2 Restart in the event of *no establishment of flame at the end of safety time*

If there is *no establishment of flame at the end of safety time*, several restarts per controlled shutdown are possible.

## 7.7 Logical combination and evaluation

Parameter access: OEM level

The two flame signal inputs (ionization and QRA7 / QRI) can be combined for the operating position *logical AND* or *logical OR* via the selection in parameter 179.

Parameter 179 = 0

Combination of flame signal inputs *logical OR*.

**OR** operation

A flame signal must be present at one of the two flame signal inputs in burner operation (after end of phase 42 to end of phase oP:xx).

As soon as a flame signal is no longer present during operation, a non-alterable lockout is performed (Loc: 2).

Parameter 179 = 1

Combination of flame signal inputs *logical AND*.

At the end of the first safety time (end of phase 42) until the end of phase 50, at least one of the two flame signals must be available. If no flame signal has been established at the end of the first safety time (end of phase 42), a non-alterable lockout is performed (Loc: 2).

At the end of the second safety time (end of phase 50) until the end of burner operation (end of phase oP:xx), both flame signals must be available. If at least one of the two flame signals extinguishes from the end of the second safety time (end of phase 50) until the end of burner operation (end of phase oP:xx), a non-alterable lockout is performed (Loc: 7).



### Note!

An **OR** operation is always used for extraneous light detection in the startup and shutdown phases.

This means that, as soon as a flame signal is detected at one of the two flame signal inputs during extraneous light detection (phase 30), a non-alterable lockout is performed (Loc: 4).

## 7.8 Parameterization of the extraneous light tolerance time in standby

Parameter	Function
216	Extraneous light tolerance time in standby

In the event of an extraneous light signal in standby, a signal is output via the LED (red/green) and via the 7-segment display (P04) / AZL2 (Ph04). Once the extraneous light tolerance time in standby has elapsed, a non-alterable lockout is performed (Loc: 4). This extraneous light tolerance time can be configured by parameter 216 in the range of 0...1,237 seconds (factory setting 30 seconds).

# 7.9 Analog input load controller terminal X65

PME75.831Ax





Figure 17: Load controller terminal X65

Parameter	Function
140	Mode display in the 7-segment display 1 = standard (program phase) 2 = flame 1 (ionization) 3 = flame 2 (QRA7 / QRI) 4 = active power (power value)
515.01	Actuator control 0 = OFF 1 = ON  <div style="background-color: #ffffcc; padding: 5px;"> <p><b>Note!</b> Setting = 0  No actuators may be connected and parameter 560 must be set to 0. The wire link Dbr3 is also required between terminal X2-09B pin 7 and terminal X2-09B pin 8.</p> </div>
560	Pneumatic combustion control 0 = OFF / 3-position step modulation 1 = PWM fan motor / analog modulation  <div style="background-color: #ffffcc; padding: 5px;"> <p><b>Note!</b> Setting = 1 No function. This selection puts the LME75 in lockout position.</p> </div> <p>2 = Air damper / analog modulation (ASZxx.3x feedback required)</p>
654	Only with analog modulating (parameter 560 = 2) Analog input (ASZxx.3x feedback required) 0 = 3-position step input 1 = 0...10 V 2 = 0...135 Ω 3 = 0...20 mA 4 = 4...20 mA with a non-alterable lockout at I < 4 mA 5 = 4...20 mA without a non-alterable lockout at I < 4 mA

The following input signals can be selected and handled via parameter 654:

- 3-position step input  
(feedback ASZxx.3x required / depending on the program sequence)
- 0...10 V
- 0...135 Ω
- 0...20 mA
- 4...20 mA with a non-alterable lockout at I < 4 mA  
(AZL2: Loc: 60)
- 4...20 mA without a non-alterable lockout at I < 4 mA



**Note!**  
Shielded cables must be used if cables are > 10 m.

Parameter access: Heating engineer level

The function of the analog input *load controller* terminal X65 can be adapted via parameter 654.

Parameter 654 = 0  
3-position step input (factory setting)

With this setting, load control takes place solely via the contact inputs for the external load controller terminal X5-03 pin 2 and 3.

Parameter 654 = 1...4  
Load control via analog input terminal X65

With this setting, load control takes place via a preset analog value.  
An analog signal (terminal X65) is only taken into account in the operating phases (oP).  
If a signal is present during startup, shutdown, standby, and in the lockout position, it is ignored.



**Note!**

Load control via analog input terminal X65 always requires an actuator with a built-in potentiometer for position feedback.

The display mode for the internal 7-segment display is defined via parameter 140.

Setting 1 = standard (program phase, factory setting)

Setting 2 = flame 1 (ION)

Setting 3 = flame 2 (QRA7 / QRI)

Setting 4 = active power

(power value, only for actuators with a built-in ASZ for position feedback)



## 7.10 External load controller (ON/OFF) terminal X5-03




Figure 18: Load controller ON/OFF terminal X5-03

Parameter	Function
225.00	Prepurge time (t1)
225.01	Multiplicator of the prepurge time (t1) (extension of prepurge time)
232	Interval (t5): Stabilization time main flame
234.00	Postpurge time (t8) (no extraneous light test)
234.01	Multiplicator of postpurge time (t8) (extension of postpurging)
239	Controlled intermittent operation after 24 hours of continuous operation 0 = OFF 1 = ON
515.00	Actuator position during prepurge time 0 = purging in low-fire 1 = purging in high-fire
515.01	Actuator control 0 = OFF 1 = ON
	<p><b>Note!</b>            Setting = 0            No actuators may be connected and parameter 560 must be set to 0.            The wire link Dbr3 is also required between terminal X2-09B pin 7 and terminal X2-09B pin 8.</p>
560	Pneumatic combustion control 0 = OFF / 3-position step modulation 1 = PWM fan motor / analog modulation
	<p><b>Note!</b>            Setting = 1            No function.            This selection puts the LME75 in lockout position.</p> <p>2 = Air damper / analog modulation (ASZxx.3x feedback required)</p>
654	Only with analog modulating (parameter 560 = 2) Analog input (ASZxx.3x feedback required) 0 = 3-position step input 1 = 0...10 V 2 = 0...135 Ω 3 = 0...20 mA 4 = 4...20 mA with a non-alterable lockout at I < 4 mA 5 = 4...20 mA without a non-alterable lockout at I < 4 mA

The load controller input is evaluated by making a 2-out-of-3 selection. This means that to trigger a control action via the actuator outputs, an ON or OFF signal must be identified within at least 2 successive cycles. As a result of this sampling process, an ON or OFF signal must be present for a time between minimum 0.3 seconds and maximum 0.45 seconds to produce an output signal change at the LME75.000Ax.

#### **Terminal X5-03 pin 1**

Heat request (input external temperature controller or limit thermostat):

The burner starts if a signal (L → terminal X5-03 pin 4) is present at pin 1.

The burner shuts down and then enters standby once a heat request is no longer present.

#### **Terminal X5-03 pin 2**

Load controller CLOSED (input *external load controller CLOSED*)

A signal (L → terminal X5-03 pin 4) at pin 2 is only taken into account in the operating phases (oP). If a signal is present during startup, shutdown, standby, and in the lockout position, it is ignored. The actuator travels toward the low-fire position, depending on the input signal. If no signal is present, the actuator stays in the position it has reached.

#### **Terminal X5-03 pin 3**

Load controller OPEN or stage 3 (input *external load controller OPEN*)

A signal (L → terminal X5-03 pin 4) at pin 3 is only taken into account in the operating phases (oP). If a signal is present during startup, shutdown, standby, and in the lockout position, it is ignored. The actuator travels toward the high-fire position, depending on the input signal. If no signal is present, the actuator stays in the position it has reached.

## 7.11 Safety loop terminal X3-04




Figure 19: Safety loop terminal X3-04

Input for the safety loop. When any of the series-connected contacts included in the loop opens, power supply to the fuel valves, the fan, and the ignition is instantly cut.

The following contacts are included in the safety loop:

- Safety limiter/safety pressure limiter
- External limit thermostat and/or pressure switch, if required
- Water shortage switch

For diagnostic purposes, the contacts of the components included in the safety loop are combined for delivering the *safety loop* signal.

If the safety loop is not closed during a heat request (load controller ON/OFF at terminal X5-03 pin 1), a non-alterable lockout is performed, error code **Loc: 22**.



### Note!

The power signal for the safety loop is only active if a heat request (load controller ON/OFF) is present at terminal X5-03 pin 1. In the lockout position, the power signal switches off too.



### Warning!

**The in-phase connection of the power supply must be observed. Failure to observe this information poses a risk of loss of device functions.**

## 8 Description of outputs on LME75



### Note!

This chapter covers the basic features of the LME75 outputs. For an exact evaluation and activation of the outputs, see the program sequences in Chapter 4 “PME75.831Ax program sequence”.

### 8.1 Fan motor terminal X2-01



Figure 20: Fan motor terminal X2-01

Output for connection of a fan motor.

### 8.2 Alarm / remote lockout reset terminal X2-03




Figure 21: Alarm / remote lockout reset terminal X2-03

#### 8.2.1 Alarm terminal X2-03 pin 3

Output at terminal X2-03 pin 3 for connecting an alarm lamp or horn. The output is activated when the LME75 is in the lockout position.



### Exception!

The output is deactivated (alarm lamp OFF), when the LME75 is in the lockout position (lockout code Loc: 10) due to an error in the output contacts (welded contact of an output relay).

#### 8.2.2 Remote lockout reset (reset) terminal X2-03 pin 1

Input at terminal X2-03 pin 1 for connecting a lockout reset button between pin 2 and pin 1. The LME75 can be reset with this button (non-alterable lockout position). Press and hold the button for >1...<3 seconds to reset.

### 8.3 Actuator terminal X2-09




Figure 22: Actuator terminal X2-09

Parameter	Function
123	Minimum load control step
259.00	Opening time of actuator (timeout)
259.01	Run time of actuator → ignition load position to low-fire position
259.02	Run time of actuator → low-fire position to ignition load position
260	Closing time of actuator (timeout)
515.00	Actuator position during prepurge time 0 = purging in low-fire 1 = purging in high-fire
515.01	Actuator control 0 = OFF 1 = ON
	<p><b>Note!</b> Setting = 0 No actuators may be connected and parameter 560 must be set to 0. The wire link Dbr3 is also required between terminal X2-09B pin 7 and terminal X2-09B pin 8.</p>
560	Pneumatic combustion control 0 = OFF / 3-position step modulation 1 = PWM fan motor / analog modulation
	<p><b>Note!</b> Setting = 1 No function. This selection puts the LME75 in lockout position.</p>
	2 = Air damper / analog modulation (ASZxx.3x feedback required)
654	Only with analog modulating (parameter 560 = 2) Analog input (ASZxx.3x feedback required) 0 = 3-position step input 1 = 0...10 V 2 = 0...135 Ω 3 = 0...20 mA 4 = 4...20 mA with a non-alterable lockout at I < 4 mA 5 = 4...20 mA without a non-alterable lockout at I < 4 mA

The actuators are powered by mains voltage delivered directly via the LME75.

### 8.3.1 Connection of feedback actuator position with ASZ in actuator at terminal X66




Figure 23: Actuator terminal X66

Type	Terminal X66			Direction of rotation	
	Pin 1 (5 V signal)	Pin 2 (signal)	Pin 3 (GND)	Clockwise	Counterclockwise
ASZ	a	b	c	●	---
ASZ	c	b	a	---	●
Terminal ASZxx30 (1 kΩ conductive plastic 90°)					

### 8.3.2 Engineering notes

Connection diagram




Figure 24: ASZ connection diagram

ASZ shown in start position.

Terminal markings:  
a = potentiometer end tap  
b = potentiometer wiper  
c = potentiometer end tap

Apply operating voltage to “a” and “c”.

*Conductive plastic* ASZ units can be destroyed if operating voltage is applied between “a → b” or “b → c”.

### 8.3.3 Pin assignment of actuators for terminal X2-09 at LME75

#### 8.3.3.1. SQN70 / SQN71

→ See diagram 6 in SQN70/SQN71 Data Sheet N7804

Terminal X2-09		Actuator		
Pin	Function	Pin	Cam	Function
1	Travel to CLOSED position	2	II	CLOSED
		3	III	Low-fire
		7	IV	Ignition position
2	Travel to low-fire position	4	III	Low-fire
3	Travel to high-fire position	1	I	High-fire
4	Feedback high-fire position/low-fire position/CLOSED position	5	---	Feedback
5	Free	---	---	---
6	Mains connection neutral (N)	N	---	Neutral
7	Travel to ignition load position	6	IV	Ignition position
8	Feedback ignition load position reached and pilot valve activation	8	IV	Ignition position

#### 8.3.3.2. SQN72

→ See diagram C in SQN72 Data Sheet N7802

Terminal X2-09		Actuator			
Pin	Function	Terminal	Pin	Cam	Function
1	Travel to CLOSED position	X2	2	II	CLOSED
		X2	3	III	Low-fire
		X1	7	IV	Ignition position
2	Travel to low-fire position	X1	4	III	Low-fire
3	Travel to high-fire position	X2	1	I	High-fire
4	Feedback high-fire position/low-fire position/CLOSED position	X2	5	---	Feedback
5	Free	---	---	---	---
6	Mains connection neutral (N)	X2	N	---	Neutral
7	Travel to ignition load position	X1	6	IV	Ignition position
8	Feedback ignition load position reached and pilot valve activation	X1	8	IV	Ignition position

### 8.3.3.3. SQM5

→ See diagram in SQM5 Data Sheet N7815

Terminal X2-09		Actuator		
Pin	Function	Pin	Cam	Function
1	Travel to CLOSED position	2	II	CLOSED
		13	III	Low-fire
		14	IV	Ignition position
2	Travel to low-fire position	3	III	Low-fire
3	Travel to high-fire position	1	I	High-fire
4	Position feedback	11	I	High-fire
		22	II	CLOSED
		23	III	Low-fire
5	Free	---	---	---
6	Mains connection neutral (N)	N	---	Neutral
7	Output ignition load	4	IV	Ignition position
8	Input ignition load	24	IV	Ignition position

### 8.3.3.4. SQM40 / SQM41

→ See diagram 8 in SQM40/SQM41 Data Sheet N7817

Terminal X2-09		Actuator		
Pin	Function	Terminal	Cam	Function
1	Travel to CLOSED position	X1-5	II	CLOSED
		X3-1	VI	Ignition position
2	Travel to low-fire position	X1-1	III	Low-fire
3	Travel to high-fire position	X1-6	I	High-fire
4	Feedback high-fire position/low-fire position/CLOSED position	X2-3	---	Feedback
5	Free	---	---	---
6	Mains connection neutral (N)	X1-4	---	Neutral
7	Travel to ignition load position	X3-3	VI	Ignition position
8	Feedback ignition load position reached and pilot valve activation	X3-2	VI	Ignition position



→ Fuel train **Gp1** "Gas pilot ignition, 1-stage, modulating"

**Example 1: LME75.000Ax with SQM40/SQM41 and ASZ**



→ See diagram 8 in SQM40/SQM41 Data Sheet N7817



**Note!**

For other possible gas trains, see Chapter *Fuel trains*.

LME75.000...



**Fuel valve control**




Figure 25: Example 1: Fuel train gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving

\*) Optional



**Note!**

When activating valve proving, the fuel valve terminal loading is restricted.

Fuel valve V1 terminal X7-04 pin 4 or fuel valve V2 terminal X7-02 pin 3

- Rated voltage            120 V AC            230 V AC
- 50/60 Hz            50/60 Hz
- Rated current            1 A                    1 A
- Power factor            cosφ >0.4            cosφ >0.4

If, on the other hand, the terminal load is not reduced (maximum rated current of 2 A, cosφ >0.4), the design lifetime is about 100,000 burner start cycles!



**Note!**

See Figure 26: Connection diagram example 1: LME75.000Ax with SQM40/SQM41 (diagram 8) and ASZ!

### PME75.831Ax

- 1-stage modulating
- With/without pilot ignition
- With/without valve proving




Figure 26: Connection diagram example 1: LME75.000Ax with SQM40/SQM41 (diagram 8) and ASZ

→ Fuel train **Gp1** "Gas pilot ignition, 1-stage, modulating"



**Example 2: LME75.000Ax with SQM40/SQM41 with external relay for pilot valve**

→ See diagram 8 in SQM40/SQM41 Data Sheet N7817



**Note!**  
For other possible gas trains, see Chapter *Fuel trains*.

LME75.000...



**Fuel valve control**




Figure 27: Example 2: Fuel train gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving

\*) Optional



**Note!**  
When activating valve proving, the fuel valve terminal loading is restricted.

Fuel valve V1 terminal X7-04 pin 4 or fuel valve V2 terminal X7-02 pin 3

- Rated voltage      120 V AC      230 V AC
- 50/60 Hz      50/60 Hz
- Rated current      1 A      1 A
- Power factor       $\cos\phi > 0.4$        $\cos\phi > 0.4$

If, on the other hand, the terminal load is not reduced (maximum rated current of 2 A,  $\cos\phi > 0.4$ ), the design lifetime is about 100,000 burner start cycles!



**Note!**

The external relay is only required if the switching capacity of the cam switch in the actuator is lower than the current draw of the pilot valve.




Figure 28: External relay connection diagram



**Note!**

See Figure 29: Connection diagram example 2: LME75.000Ax with SQM40/SQM41 (diagram 8) with external relay for pilot valve!

**PME75.831Ax**

- 1-stage modulating
- With/without pilot ignition
- With/without valve proving





Figure 29: Connection diagram example 2: LME75.000Ax with SQM40/SQM41 (diagram 8) with external relay for pilot valve

- Fuel train **Gp1** "Gas pilot ignition, 1-stage, modulating"
- Fuel train **Lo** "Light oil direct ignition, 1-stage, modulating"

**Example 3: LME75.000Ax with SQM40/SQM41, oil fuel 1-stage/gas fuel 1-stage or modulating**

→ See diagram 8 in SQM40/SQM41 Data Sheet N7817



**Fuel valve control**




Figure 30: Example 3: Fuel train direct ignition with light fuel oil (Lo), 1-stage/gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving

\*) Optional

**Note!**  
When activating valve proving, the fuel valve terminal loading is restricted.

Fuel valve V1 terminal X7-04 pin 4 or fuel valve V2 terminal X7-02 pin 3

• Rated voltage	120 V AC	230 V AC
	50/60 Hz	50/60 Hz
• Rated current	1 A	1 A
• Power factor	cosφ >0.4	cosφ >0.4

If, on the other hand, the terminal load is not reduced (maximum rated current of 2 A, cosφ >0.4), the design lifetime is about 100,000 burner start cycles!

**Note!**  
See Figure 31: Connection diagram example 3: LME75.000Ax with SQM40/SQM41, oil/gas fuel modulating!

**PME75.831Ax**

- Fuel 1 gas: 1-stage or modulating
- Fuel 2 oil: 1-stage
- Fuel 1 gas: With/without pilot ignition
- With/without valve proving
- Fuel 1 gas: With valve proving, modulating
- Fuel 2 oil: Without valve proving, 1-stage
- 2 independent ignition load positions
- 2 independent low-fire positions
- One high-fire position for both fuels







Figure 31: Connection diagram example 3: LME75.000Ax with SQM40/SQM41, oil/gas fuel modulating

- Fuel train **Gp1** "Gas pilot ignition, 1-stage, modulating",
- Fuel train **Lo** "Light oil direct ignition, 1-stage, modulating"

**Example 4: LME75.000Ax with SQM40/SQM41 gas fuel 1-stage or modulating, oil fuel 2-stage**

→ See diagram 8 in SQM40/SQM41 Data Sheet N7817

LME75.000...



**Fuel valve control**




Figure 32: Example 4: Fuel train direct ignition with light fuel oil (Lo), 2-stage/gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving

\*) Connection for gas fuel only

\*) Optional





**Note!**

When activating valve proving, the fuel valve terminal loading is restricted.

Fuel valve V1 terminal X7-04 pin 4 or fuel valve V2 terminal X7-02 pin 3

- |                 |                     |                     |
|-----------------|---------------------|---------------------|
| • Rated voltage | 120 V AC            | 230 V AC            |
|                 | 50/60 Hz            | 50/60 Hz            |
| • Rated current | 1 A                 | 1 A                 |
| • Power factor  | $\cos\varphi > 0.4$ | $\cos\varphi > 0.4$ |

If, on the other hand, the terminal load is not reduced (maximum rated current of 2 A,  $\cos\varphi > 0.4$ ), the design lifetime is about 100,000 burner start cycles!



**Note!**

The fuel valve for oil is activated by the actuator cam VI directly in the second stage.



**Note!**

See Figure 33: Connection diagram example 4: LME75.000Ax with SQM40/SQM41 gas fuel modulating, oil 2-stage!

**PME75.831Ax**

- 1-stage gas modulating/oil 2-stage
- Fuel 1 gas: With/without pilot ignition
- With/without valve proving
- Fuel 1 with valve proving (gas), modulating
- Fuel 2 without valve proving (oil), 2-stage
- Common ignition load positions for both fuels
- 2 independent low-fire positions
- Common low-fire position for both fuels




Figure 33: Connection diagram example 4: LME75.000Ax with SQM40/SQM41 gas fuel modulating, oil 2-stage

→ Fuel train **Gp1** "Gas direct ignition or pilot ignition, 1-stage"

**Example 5: LME75.000Ax with PME75.831Ax without actuator**



**Note**  
 Operation without actuator control (parameter 515.01 = 0)!  
 A Dbr3 wire link is required at terminal X2-09B from pin 7 to pin 8 required.

**PME75.831Ax**

- 1-stage, direct ignition or pilot ignition
- Without actuator
- With/without valve proving



Figure 34: Connection diagram example 5: for LME75.000Ax with PME75.831Ax without actuator

The actuator function can be deactivated using parameter 515.01.

Parameter access OEM level

Parameter 515.01 = 0

Actuator deactivated (setting for applications without actuator)

Parameter 515.01 = 1

Actuator activated

The following conditions must be observed for the PME75.831Ax program sequence with the actuator function deactivated:

- Wire link Dbr3 required between terminal X2-09 pin 7 and terminal X2-09 pin 8
- The parameter (pneumatic ratio control operating mode)  
Parameter 560 = 0
- If an input signal is present at the 3-position step inputs, for load controller ON at terminal X5-03 pin 3 or load controller CLOSED at terminal X5-03 pin 2, a mains voltage signal is issued at the actuator high-fire terminal X2-09 pin 3 and actuator low-fire terminal X2-09 pin 2 outputs, see table below:

Output request		Actuator control reaction	
Load controller OPEN (Terminal X5-03 pin 3)	Load controller CLOSED (Terminal X5-03 pin 2)	Actuator low-fire (Terminal X2-09 pin 2)	Actuator high-fire (Terminal X2-09 pin 3)
OFF	OFF	OFF	OFF
OFF	ON	ON	OFF
ON	OFF	OFF	ON
ON	ON	ON (prio)	OFF

**Warning!**

In applications without an actuator, no other components may be connected at the actuator control outputs (terminal X2-09 pin 1...4). To ensure protection against electric shock hazards, all unused connections must be fitted with corresponding AGG plugs (see Basic Documentation LME75/LME76 (P7156) Chapters *Safety notes* and *Installation notes*).

**Note**

Operation without actuator control (parameter 515.01 = 0)!

A Dbr3 wire link is required at terminal X2-09B from pin 7 to pin 8 required.

## 8.4 Ignition transformer terminal X4-02




Figure 35: Ignition transformer terminal X4-02

Parameter	Function
226	Preignition time
257	Postignition time + 0.3 seconds

Output for the connection of ignition transformers or electronic ignition modules.

## 8.5 Safety valve terminal X6-03




Figure 36: Safety valve terminal X6-03

Output for connection of a safety valve, e.g., for liquefied gas.



### Note!

The safety valve is only active if a heat request (load controller ON/OFF) is present at terminal X5-01 pin 3.

## 8.6 Pilot valve PV terminal X7-01 / X7-04

→ For fuel trains **Gp1**




Figure 37: Pilot valve PV terminal X7-01

→ For fuel trains **Gp2**




Figure 38: Pilot valve PV terminal X7-04

Parameter	Function
230	Interval (t4): Stabilization time pilot flame
231	Interval (t9): Second safety time
232	Interval (t5): Stabilization time main flame

Outputs for connection of the pilot valve, depending on the fuel train selected.



### Note!

In the case of applications with gas pilot ignition and fuel train **Gp1**, the switching contact on the connected actuator switches pilot valve PV on terminal X7-01.

Please observe the maximum permissible contact rating of the connected switching cam for the actuator in use.

If the switching capacity of the cam switch in the actuator is lower than the current draw of the pilot valve PV, an external relay may be connected.

Please also observe the maximum permissible contact rating for terminal X7-01:

Rated voltage	120 V AC	230 V AC
	50/60 Hz	50/60 Hz
Rated current	1 A	1 A
Power factor	$\cos\varphi > 0.4$	$\cos\varphi > 0.4$

## 8.7 Fuel valve V1 terminal X7-02 / X7-04

→ For fuel trains **Gp2**




Figure 39: Fuel valve V1 terminal X7-02

→ For fuel trains **G / Gp1**



Figure 40: Fuel valve V1 terminal X7-04

Parameter	Function
230	Interval (t4): Stabilization time pilot flame
231	Interval (t9): Second safety time
232	Interval (t5): Stabilization time main flame

Outputs for connection of fuel valve depending on the fuel train selected.

## 8.8 Fuel valve V2 terminal X7-01 / X7-02

→ For fuel trains **G**




Figure 41: Fuel valve V2 terminal X7-01

→ For fuel trains **Gp1**



Figure 42: Fuel valve V2 terminal X7-02

Parameter	Function
230	Interval (t4): Stabilization time pilot flame
231	Interval (t9): Second safety time
232	Interval (t5): Stabilization time main flame

Outputs for connection of fuel valve depending on the fuel train selected.



### Note!

For gas direct ignition (G), a wire link Dbr2 between terminal X7-01 pin 3 and terminal X7-02 pin 3 is required.

Thereby, the fuel valve V2 is switched on via terminal X7-01 or via the switching contact on the connected actuator.

Please observe the maximum permissible contact rating of the connected switching cam for the actuator in use.

If the switching capacity of the cam switch in the actuator is lower than the current draw of the fuel valve V2, an external relay may be connected.

Please also observe the maximum permissible contact rating for terminal X7-01:

Rated voltage	120 V AC	230 V AC
	50/60 Hz	50/60 Hz
Rated current	1 A	1 A
Power factor	$\cos\varphi > 0.4$	$\cos\varphi > 0.4$




## 9 Time table and settings

Times in seconds																
Parameter			225.00	225.01	226	257	230	232	234.00	234.01	231	224	259.00	259.01	259.02	260
Type PME75.831Ax	tw	TSA	t1	t3	t3n	t4	t5	t8	t9	t10	t11					t12
		max.	4) min.	min.	approx.	min.	min.	5) min.	approx.	approx.	approx.	approx.	approx.	approx.	approx.	approx.
Requirement	2.5	3	30	2	2.5	3	8.5	0	3	12	65	15	15	65		
Factory setting	---	t3n+0.45	29.106+2.1	1	2.058	2.205+0.3	3.234	8.82	0	1	2.94	12.054	67.914	14.994	14.994	67.914
Max.	2.5	14	1237+2.1	255	37.485	13.23+0.3	74.97	74.97	1237	255	74.97	13.818	1237	37.485	37.485	1237
Min.	---	---	0+2.1	1	1.029	0+0.3	0	2.058	0	1	0	0	0	0	0	0
Increment	---	---	4.851	1	0.147	0.147	0.294	0.294	4.851	1	0.294	0.294	4.851	0.147	0.147	4.851

Times in seconds								
Parameter				243	245	244	242	217.01
Type PME75.831Ax	t22			td1	td2	td3	td4	ION/QRI/QRA7 FFRT (TSB)
	1)/3)	2)	3)	min.	max.	max.		
Requirement	t9+217.01	---	---	10	3	1		
Factory setting	---	---	---	10.29	2.646	0 + 1		
Max.	---	0.45	0.45	37.485	2.646	13.818 + 1		
Min.	---	0.3	---	1.029	0	---		
Increment	---	---	---	0.147	0.147	0.147		

Parameter number	Function	Factory setting
216	Extraneous light tolerance time in standby	30 s
217.01	Flame signal flame-out response time (extension) 0 = maximum 1 second with ionization probe ≥ 0 = additional extension to reaction to a flame fault	0 s
218	Time for controlled intermittent operation	80050.31 s
222	Prepurging 0 = inactive 1 = active	1
223	Gas pressure switch-min – response to loss 0 = safety shutdown and start prevention 1 = non-alterable lockout	1
225.00	Prepurge time (t1)	30 s
225.01	Multiplicator of the prepurge time (t1) (extension of prepurge time)	1
230	Interval (t4): Stabilization time pilot flame	3.234 s
231	Interval (t9): Second safety time	2.94 s
232	Interval (t5): Stabilization time main flame	8.82 s
234.00	Postpurge time (t8) (no extraneous light test)	0 s
234.01	Multiplicator of postpurge time (t8) (extension of postpurging)	1
235.00	Air pressure switch input 0 = no evaluation of the air pressure switch during operation (evaluation only during prepurging and, if necessary, postpurging) 1 = evaluation of the air pressure switch during prepurging and postpurging, as well as when in the operating position	1
235.01	Air pressure switch – response time to loss 0 = typically 0.7 seconds ≥ 0 = additional delay in reaction to faulty air pressure switch	0.294 s
236	Input pressure switch-min 0 = permanent evaluation 1 = in operation only (after second safety time)	0

Parameter number	Function	Factory setting
237.00	Input for POC / CPI (not adjustable) 0 = inactive	0
237.01	Function input valve proving or gas pressure switch-max terminal X2-02 0 = deactivation of valve proving (via external switching contact) 1 = input for gas pressure switch-max.	0
239	Controlled intermittent operation after 24 hours of continuous operation 0 = OFF 1 = ON	0
240	Restart in the event of loss of flame during operation and in the event of no flame at the end of the safety time 0 = no restart 1 = no restart 2 = 1x restart 3 = 2x restart 4 = 3x restart	0
241.00	Valve proving 0 = OFF 1 = ON	1
241.01	Valve proving 0 = during prepurge time 1 = during postpurge time	0
241.02	Valve proving 0 = according to parameter 241.01 1 = during prepurge time and postpurge time	0
515.00	Actuator position during prepurge time 0 = purging in low-fire 1 = purging in high-fire	1
515.01	Actuator control 0 = OFF 1 = ON	1
	 <p><b>Note!</b> Setting = 0 No actuators may be connected and parameter 560 must be set to 0. The wire link Dbr3 is also required between terminal X2-09B pin 7 and terminal X2-09B pin 8.</p>	

## Key

FFRT	Flame failure response time
tw	Waiting time
TSA	Startup safety time
TSB	Operation safety time
t1	Prepurge time
t3	Preignition time
t3n	Postignition time parameter 257 + 0.3 seconds
t4	Interval (t4): Stabilization time pilot flame
t5	Interval (t5): Stabilization time main flame
t8	Postpurge time
t9	Interval (t9): Second safety time
t10	Specified time air pressure switch message (timeout)
t11	Opening time of actuator (timeout)
t12	Closing time of actuator (timeout)
t22	Second safety time
td1	Test time atmospheric pressure
td2	Test time gas pressure
td3	Test space filling
td4	Test space evacuating
1)	Response time to a change of signal by the air pressure switch contact (opens) and flame-out response time in the event of loss of flame
2)	Response time to a change of signal by the inputs (e.g., pressure switch-min)
3)	Flame detection time
4)	Minimum time $td1 + td2 + td3 + td4$ if: Parameter 241.00 = 1 (ON), after Power ON, with a non-alterable lockout, parameter 234 (postpurge time) = 0 (postpurging) or parameter 241.01 = 0
5)	Minimum time $td1 + td2 + td3 + td4$ if: Parameter 241.00 = 1 (ON) and parameter 234 (postpurge time) > 0 (postpurging) and parameter 241.01 = 1
Parameter 259.01	Actuator running time of ignition load in a position > low-fire
Parameter 259.02	Actuator running time of low-fire in a position > ignition load

# 10 Inputs and outputs/internal connection diagram




Figure 43: LME75.000Ax: Inputs and outputs/internal connection diagram

# 11 Parameter list (AZL2/ACS410)

## Abbreviations for password level:

HF	Heating engineer
OEM	Manufacturer of the individual product

Parameter number	Function	Edit	Value range		Increment	Factory setting	Password level reading from level	Password level writing from level
			Min.	Max.				
000	Internal parameters							
041	Heating engineer (HF) password (4 characters)	Adjustable	xxxx	xxxx	---	On request	---	OEM
042	OEM password (5 characters)	Adjustable	xxxxx	xxxxx	---	On request	---	OEM
060	Backup/restore	Adjustable	Restore	Backup	---	---	---	HF



Parameter number	Function	Edit	Value range		Increment	Factory setting	Password level reading from level	Password level writing from level
			Min.	Max.				
100	General							
101	Type (ASN) of the basic unit	Read only	xxxxx.xxxxx	xxxxx.xxxxx	---	---	Via ACS410 only	---
102	Identification date	Read only	---	---	---	---	Info	---
103	Identification number	Read only	0	9999	1	0	Info	---
113	Burner identification • Can be read via AZL2 • Can be adjusted via ACS410	Read only/adjustable	0	99999999	1	-----	Info	OEM via ACS410
119	Type of OEM program module	Read only	xxxxx.xxxxx	xxxxx.xxxxx	--	PME75.831Ax	Via ACS410 only	---
120	Type of program module	Read only	xxxxx.xxxxx	xxxxx.xxxxx	--	PME75.831Ax	Via ACS410 only	---
123	Minimum load control step	Adjustable	1%	10%	0.1%	2%	HF	HF
140	Mode display in the 7-segment display 1 = standard (program phase) 2 = flame 1 (ionization) 3 = flame 2 (QRA7 / QRI) 4 = active power (power value)	Adjustable	1	4	1	1	HF	HF
164	Number of startups	Resettable	0	999999	1	0	Info	Info
166	Total number of startups	Read only	0	999999	1	0	Info	---
170.00	Relay contact K8 switching cycles (SA-KL: X2-09 pin 2)	Read only	0	99999999	1	0	Info	---
170.01	Relay contact K7 switching cycles (SA-NL: X2-09 pin 3)	Read only	0	99999999	1	0	Info	---
170.02	Relay contact K2 switching cycles (PV: X7-01 pin 3)	Read only	0	99999999	1	0	Info	---
170.03	Relay contact K1 switching cycles (SV: X6-03 pin 3)	Read only	0	99999999	1	0	Info	---
171	Signaling of "Switching cycle exceeded" for one of the relay contact counters (parameters 170.00 to 170.03) → not active	Read only	0	99999999	1	1000000	Info	---
179	Logical combination of both flame signal amplifier channels 0 = flame signal amplifier channels are logically combined with an <b>OR</b> operation (ionization <b>OR</b> QRA7 / QRI) 1 = flame signal amplifier channels are logically combined with an <b>AND</b> operation (ionization <b>AND</b> QRA7 / QRI)	Adjustable	0	1	1	0	HF	OEM
180	Test interval for flame detector QRA7 / QRI 0 = ≤5 minutes 1 = ≤5 seconds	Adjustable	0	1	1	0	HF	OEM

Parameter number	Function	Edit	Value range		Increment	Factory setting	Password level reading from level	Password level writing from level
			Min.	Max.				
200	Burner control LME75							
216	Extraneous light tolerance time in standby	Adjustable	0 s	1237 s	4.851 s	29.106 s	HF	HF
217.00	Flame signal flame-on response time (extension) (not adjustable) 0 = maximum 1 second with ionization probe, QRA7 or QRI	Read only	0 s	0 s	0.147 s	0 s	HF	---
217.01	Flame signal flame-out response time (extension) 0 = maximum 1 second with ionization probe, QRA7 or QRI ≥ 0 = additional extension to reaction to a flame fault	Adjustable	0 s	13.818 s	0.147 s	0 s	HF	OEM
218	Time for controlled intermittent operation	Adjustable	0 s	80050.31 s	358.97 s	80050.31 s	HF	OEM
222	Prepurging 0 = inactive 1 = active	Adjustable	0	1	1	1	HF	HF
223	Gas pressure switch-min – response to loss 0 = safety shutdown and start prevention 1 = non-alterable lockout	Adjustable	0	1	1	1	HF	HF
224	Specified time air pressure switch	Adjustable	0 s	13.818 s	0.294 s	12.054 s	HF	OEM
225.00	Prepurge time (t1)	Adjustable	0 s	1237 s	4.851 s	29.106 s	HF	OEM
225.01	Multiplicator of the prepurge time (t1) (extension of prepurge time)	Adjustable	1	255	1	1	HF	OEM
226	Preignition time	Adjustable	1.029 s	37.485 s	0.147 s	2.058 s	HF	OEM
230	Interval (t4): Stabilization time pilot flame	Adjustable	0 s	74.97 s	0.294 s	3.234 s	HF	OEM
231	Interval (t9): Second safety time	Adjustable	0 s	74.97 s	0.294 s	2.94 s	HF	OEM
232	Interval (t5): Stabilization time main flame	Adjustable	2.058 s	74.97 s	0.294 s	8.82 s	HF	OEM
234.00	Postpurge time (t8) (no extraneous light test)	Adjustable	0 s	1237 s	4.851 s	0 s	HF	HF
234.01	Multiplicator of postpurge time (t8) (extension of postpurging)	Adjustable	1	255	1	1	HF	HF
235.00	Air pressure switch input 0 = no evaluation of the air pressure switch during operation (evaluation only during prepurging and, if necessary, postpurging) 1 = evaluation of the air pressure switch during prepurging and postpurging, as well as when in the operating position	Adjustable	0	1	1	1	HF	HF



Parameter number	Function	Edit	Value range		Increment	Factory setting	Password level reading from level	Password level writing from level
			Min.	Max.				
235.01	Air pressure switch – response time to loss 0 = typically 0.7 seconds ≥ 0 = additional delay in response to faulty air pressure switch	Adjustable	0 s	2.058 s	0.147 s	0.294 s	HF	HF
236	Input pressure switch-min 0 = permanent evaluation 1 = in operation only (after second safety time)	Adjustable	0	1	1	0	HF	HF
237.00	Input for POC / CPI (not adjustable) 0 = inactive	Read only	0	0	1	0	HF	---
237.01	Function input valve proving or gas pressure switch-max terminal X2-02 0 = deactivation of valve proving (via external switching contact) 1 = input for gas pressure switch-max.	Adjustable	0	1	1	0	HF	OEM
239	Controlled intermittent operation after 24 hours of continuous operation 0 = OFF 1 = ON	Adjustable	0	1	1	0	HF	OEM
240	Restart in the event of loss of flame during operation and in the event of no flame at the end of the safety time 0 = no restart 1 = no restart 2 = 1x restart 3 = 2x restart 4 = 3x restart	Adjustable	0	4	1	0	HF	HF
241.00	Valve proving 0 = OFF 1 = ON	Adjustable	0	1	1	1	HF	HF
241.01	Valve proving 0 = during prepurge time 1 = during postpurge time	Adjustable	0	1	1	0	HF	HF
241.02	Valve proving 0 = according to parameter 241.01 1 = during prepurge time and postpurge time	Adjustable	0	1	1	0	HF	HF
242	Valve proving – test space evacuating (td4)	Adjustable	0 s	2.646 s	0.147 s	2.646 s	HF	HF
243	Valve proving – test time atmospheric pressure (td1)	Adjustable	1.029 s	37.485 s	0.147 s	10.290 s	HF	HF
244	Valve proving – test space filling (td3)	Adjustable	0 s	2.646 s	0.147 s	2.646 s	HF	HF
245	Valve proving – test time gas pressure (td2)	Adjustable	1.029 s	37.485 s	0.147 s	10.290 s	HF	HF

Parameter number	Function	Edit	Value range		Increment	Factory setting	Password level reading from level	Password level writing from level
			Min.	Max.				
257	Postignition time + 0.3 seconds	Adjustable	0 s	13.23 s	0.147 s	2.205 s	HF	OEM
259.00	Opening time of actuator (timeout)	Adjustable	0 s	1237 s	4.851 s	67.914 s	HF	OEM
259.01	Run time of actuator → Ignition load position to low-fire position	Adjustable	0 s	37.485 s	0.147 s	14.994 s	HF	OEM
259.02	Run time of actuator → Low-fire position to ignition load position	Adjustable	0 s	37.485 s	0.147 s	14.994 s	HF	OEM
260	Closing time of actuator (timeout)	Adjustable	0 s	1237 s	4.851 s	67.914 s	HF	OEM

Parameter number	Function	Edit	Value range		Increment	Factory setting	Password level reading from level	Password level writing from level
			Min.	Max.				
500	Ratio control							
515.00	Actuator position during prepurge time 0 = purging in low-fire 1 = purging in high-fire	Adjustable	0	1	1	1	HF	OEM
515.01	Actuator control 0 = OFF 1 = ON   Note! Setting = 0 No actuators may be connected and parameter 560 must be set to 0. The wire link Dbr3 is also required between terminal X2-09B pin 7 and terminal X2-09B pin 8.	Adjustable	0	1	1	1	HF	OEM
560	Pneumatic combustion control 0 = OFF / 3-position step modulation 1 = PWM fan motor / analog modulation   Note! Setting = 1 No function. This selection puts the LME75 in lockout position.  2 = Air damper / analog modulation (ASZxx.3x potentiometer feedback required)	Adjustable	0	2	1	0	HF	HF
600	Power setting							
654	Only with analog modulating (parameter 560 = 2) Analog input (ASZxx.3x feedback required) 0 = 3-position step input 1 = 0...10 V 2 = 0...135 Ω 3 = 0...20 mA 4 = 4...20 mA with a non-alterable lockout at I < 4 mA 5 = 4...20 mA without a non-alterable lockout at I < 4 mA	Adjustable	0	5	1	0	HF	HF

Parameter number	Function	Edit	Value range		Increment	Factory setting	Password level reading from level	Password level writing from level
			Min.	Max.				
700	Error history							
701	Current error: 00 = error code 01 = startup meter reading 02 = MMI phase 03 = power value	Read only	2 0 --- 0%	255 999999 --- 100%	1 1 --- 1	---	Service	---
702	Latest error in the history 00 = error code 01 = startup meter reading 02 = MMI phase 03 = power value	Read only	2 0 --- 0%	255 999999 --- 100%	1 1 --- 1	---	Service	---
.								
.								
.								
711	Oldest error in the history 00 = error code 01 = startup meter reading 02 = MMI phase 03 = power value	Read only	2 0 --- 0%	255 999999 --- 100%	1 1 --- 1	---	Service	---






Parameter number	Function	Edit	Value range		Increment	Factory setting	Password level reading from level	Password level writing from level
			Min.	Max.				
900	Process data							
903	Modulating operation: Current output (0...100% in 1% increments)	Read only	0%	100%	1%	---	Via ACS410 only	---
908	Target fan speed (standardized)	Read only	0%	100%	1%	---	Via ACS410 only	---
920	Current signal of PWM fan motor	Read only	0%	100%	1%	---	Service	---
922	Position of the actuators	Read only	0%	100%	1%	---	Via ACS410 only	---
923	Target position of the actuators	Read only	0%	100%	1%	---	Via ACS410 only	---
935	Absolute speed of PWM fan motor	Read only	0	9999	rpm	---	Service	---
936	Standardized speed of PWM fan motor	Read only	0%	100%	0.01%	---	Service	---
944	Output of the external load controller	Read only	0%	100%	1%	---	Via ACS410 only	---
951	Mains voltage	Read only	0 V	LME75.000A1: 175 V LME75.000A2: 350 V	1 V	---	Service	---
954.00	Intensity of flame for ionization probe (0...100%)	Read only	0%	100%	1%	---	Service	---
954.01	Intensity of flame QRA7 / QRI (0...100%)	Read only	0%	100%	1%	---	Service	---

## 12 Error code list

Error code		Plain text	Possible cause
AZL2	LED display (alternating)		
Loc: 2	Loc 2	No flame at end of safety time	<ul style="list-style-type: none"> <li>Faulty or soiled fuel valves</li> <li>Defective, soiled or incorrectly connected flame detector</li> <li>Poor adjustment of burner, no fuel</li> <li>Faulty ignition</li> </ul>
Loc: 3	Loc 3	Air pressure faulty (air pressure switch welded in no-load position, decrease to specified time) (air pressure switch flame-on response time)	Air pressure switch faulty <ul style="list-style-type: none"> <li>Loss of air pressure signal after specified time</li> <li>Air pressure switch welded in no-load position</li> </ul>
Loc: 4	Loc 4	Extraneous light	<ul style="list-style-type: none"> <li>Extraneous light during burner startup / standby or after extraneous light tolerance time has elapsed (parameter 216) in standby</li> <li>Extraneous light due to defective flame detector (QRA7/QRI)</li> </ul>
Loc: 5	Loc 5	Air pressure faulty, air pressure switch welded in operating position	Time supervision air pressure switch <ul style="list-style-type: none"> <li>Air pressure switch welded in operating position</li> </ul>
Loc: 6	Loc 6	Actuator fault	<ul style="list-style-type: none"> <li>Actuator faulty or blocked</li> <li>Faulty connection</li> <li>Faulty adjustment</li> </ul>
Loc: 7	Loc 7	Loss of flame	To many losses of flame during operation (limitation of restarts) <ul style="list-style-type: none"> <li>Faulty or soiled fuel valves</li> <li>Faulty or soiled flame detector</li> <li>Poor adjustment of burner</li> </ul>
Loc: 10	Loc 10	Non-volatile lockout with alarm output switched on at terminal X2-03 pin 3 (fault lamp ON)	<ul style="list-style-type: none"> <li>Wiring error or internal error, other errors</li> <li>Error due to failed flame detector test (QRA7/QRI)</li> </ul>
Loc: 10	Loc 10	Non-volatile lockout with alarm output switched off at terminal X2-03 pin 3 (fault lamp OFF)	Output contact error (welded contact of an output relay)
Loc: 12	Loc 12	Valve proving error in fuel valve V1	Fuel valve V1 leaking
Loc: 13	Loc 13	Valve proving error in fuel valve V2	Fuel valve V2 leaking
Loc: 20	Loc 20	Gas pressure switch-min open	Gas shortage
Loc: 21	Loc 21	Gas pressure switch-max open	Gas pressure has exceeded maximum limit
Loc: 22	Loc 22	Safety loop open	<ul style="list-style-type: none"> <li>External limit thermostat or pressure switch open</li> <li>Safety temperature limiter has tripped</li> </ul>

Error code		Plain text	Possible cause
AZL2	LED display (alternating)		
Loc: 60	Loc 60	Analog load controller source 4...20 mA, I < 4 mA	Wire breakage
Loc: 138	Loc 138	Restore process successful	Restore process successful
Loc: 139	Loc 139	No PME75 detected	No PME75 plugged in
Loc: 167	Loc 167	Manual locking	Manual locking
Loc: 206	Loc 206	AZL2 incompatible	Use the latest version
rSt Er1	rSt Er1	Error in compatibility between PME75 and LME75 during restore process	Program sequence of PME75 does not match the LME75
rSt Er2	rSt Er2	Error in compatibility between PME75 and LME75 during restore process	LME75 hardware does not match the PME75
rSt Er3	rSt Er3	Error during restore process	<ul style="list-style-type: none"> <li>• PME75 faulty</li> <li>• PME75 removed during restore process</li> </ul>
bAC Er3	bAC Er3	Error in compatibility between PME75 and LME75 during backup process	Program sequence of PME75 does not match the LME75
Err PrC	Err PrC	Fault in PME75	<ul style="list-style-type: none"> <li>• Error in data content of the PME75</li> <li>• No PME75 plugged in</li> </ul>

# 13 Key

AL	Alarm device
Dbr...	Wire link
	Lockout reset button (info button)
 /reset (EK1)	
EK2	Remote lockout reset button
FSV	Flame signal amplifier
ION	Ionization probe
Kx	Relay contact
LED	3-color signal lamp
LP	Air pressure switch
LR	Load controller
LR-OPEN	Load controller OPEN position
LR-CLOSED	Load controller CLOSED position
M	Fan motor
NT	Power supply unit
P LT	Pressure switch valve proving
Pmax	Pressure switch-max
Pmin	Pressure switch-min
PV	Pilot valve
QRA7	UV flame detector
QRI	Infrared flame detector
R	Control thermostat or pressurestat
SA	Actuator
SA-KL	Actuator low-fire
SA-NL	Actuator high-fire
SA-R	Actuator feedback
SA-Closed	Actuator CLOSED
SA-ZL	Actuator ignition load
SK	Safety loop
SV	Safety valve
V1	Fuel valve
V2	Fuel valve
Z	Ignition transformer
	Input/output signal 1 (ON)
	Input/output signal 0 (OFF)
	Permissible signal 1 (ON) or 0 (OFF)



# 14 List of figures

---

Figure 1: Program sequence for fuel trains <b>G</b> without/with valve proving, <b>Gp1</b> with valve proving, and <b>Gp2</b> without valve proving .....	7
Figure 2: Program sequence for fuel trains <b>G</b> without/with valve proving, <b>Gp1</b> with valve proving, and <b>Gp2</b> without valve proving .....	8
Figure 3: Program sequence for fuel trains <b>G</b> without/with valve proving, <b>Gp1</b> with valve proving, and <b>Gp2</b> without valve proving .....	9
Figure 4: Program sequence for fuel trains <b>G</b> without/with valve proving, <b>Gp1</b> with valve proving, and <b>Gp2</b> without valve proving .....	10
Figure 5: Program sequence for fuel trains <b>G</b> without/with valve proving, <b>Gp1</b> with valve proving, and <b>Gp2</b> without valve proving .....	11
Figure 6: Fuel train gas direct ignition (G), 1-stage or modulating, without valve proving .....	15
Figure 7: Fuel train gas pilot ignition 2 (Gp2), 1-stage or modulating, without valve proving.....	16
Figure 8: Fuel train gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving, alternately lighting pilot burner.....	17
Figure 9: Fuel train gas direct ignition 1 (G), 1-stage or modulating, with valve proving .....	18
Figure 10: Air pressure switch terminal X3-02.....	20
Figure 11: Gas pressure switch-min terminal X5-01.....	24
Figure 12: Gas pressure switch-max or valve proving terminal X2-02 .....	26
Figure 13: Pressure switch valve proving terminal X9-04.....	29
Figure 14: Valve proving with separate pressure switch .....	30
Figure 15: Ionization probe terminal X10-06.....	33
Figure 16: QRA7 / QRI terminal X10-05.....	34
Figure 17: Load controller terminal X65.....	38
Figure 18: Load controller ON/OFF terminal X5-03.....	41
Figure 19: Safety loop terminal X3-04 .....	43
Figure 20: Fan motor terminal X2-01 .....	44
Figure 21: Alarm / remote lockout reset terminal X2-03 .....	44
Figure 22: Actuator terminal X2-09.....	45
Figure 23: Actuator terminal X66.....	46
Figure 24: ASZ connection diagram .....	46
Figure 25: Example 1: Fuel train gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving .....	49
Figure 26: Connection diagram example 1: LME75.000Ax with SQM40/SQM41 (diagram 8) and ASZ .....	50
Figure 27: Example 2: Fuel train gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving .....	51

Figure 28: External relay connection diagram.....	52
Figure 29: Connection diagram example 2: LME75.000Ax with SQM40/SQM41 (diagram 8) with external relay for pilot valve .....	53
Figure 30: Example 3: Fuel train direct ignition with light fuel oil (Lo), 1-stage/gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving.....	54
Figure 31: Connection diagram example 3: LME75.000Ax with SQM40/SQM41, oil/gas fuel modulating.....	55
Figure 32: Example 4: Fuel train direct ignition with light fuel oil (Lo), 2-stage/gas pilot ignition 1 (Gp1), 1-stage or modulating, with valve proving.....	56
Figure 33: Connection diagram example 4: LME75.000Ax with SQM40/SQM41 gas fuel modulating, oil 2-stage.....	58
Figure 34: Connection diagram example 5: for LME75.000Ax with PME75.831Ax without actuator.....	59
Figure 35: Ignition transformer terminal X4-02.....	61
Figure 36: Safety valve terminal X6-03 .....	61
Figure 37: Pilot valve PV terminal X7-01 .....	62
Figure 38: Pilot valve PV terminal X7-04 .....	62
Figure 39: Fuel valve V1 terminal X7-02.....	63
Figure 40: Fuel valve V1 terminal X7-04.....	63
Figure 41: Fuel valve V2 terminal X7-01.....	64
Figure 42: Fuel valve V2 terminal X7-02.....	64
Figure 43: LME75.000Ax: Inputs and outputs/internal connection diagram .....	69